

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

## **Group Number Assessment**

(In accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing.

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

Test Sponsor: FEBRIK Test Number:

Minosstraat 20 5048 CK Tilburg

The Netherlands

Issue Date : 27/02/2020

Print Date : 18/03/2020

The Netherlands

Sponsor Product Clients Ref : "Apparel"

Wadded double knit fabric

Colour: Taupe

End Use: Wall Covering/Upholstery

Nominal Composition: 60% Polyester filling, 21% New Wool, 11% Nylon, 7% Polyester, 1%

Elastane

Nominal Mass per Unit Area/Density: 900g/m2

Nominal Thickness: 5mm

Product Group Number Classification :

Average Specific Extinction Area: 70.2 m²/kg

S140V]

Sean Bassett Division Manager

42221

20-000566

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. It's transmission is not intended to place the contents into the public domain.