

Laboratory approved by the Ministry for the Interior

JO of February 10, 2007

OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE

Of A MATERIAL ENVISAGED IN ARTICLE 5

DECREE OF November 21, 2002

N° CM - 20 - P - 025

et 1 annexe de 4 pages.

Page 1

Valid 5 years as from jeudi 13 février 2020

Material presents by : **SAHCO GmbH**Kreuzburger str. 17-19
90471 NUREMBERGTrade mark: **MOUNTAIN**

Summary description

Kind of textile woven

Composition 100% polyester FR

Mass per unit area 290 g/m²

Tickness 2 mm

Color tous coloris

Nature of the test : Electrical burner test
Flame persistence
Dripping testClassification : **M1**

Observations : /

Durability of the classification (Article 5 de l'annexe 2) Not limited

Usual term Walls hung covering, sheers, curtains,...

Cleaning conditions Washable with water

Taking into account the criteria resulting from the tests annexed described in the test report N°FE 20-0022-0113

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"

Champs-sur-Marne, le mercredi 26 février 2020

Technicienne d'essais
du Laboratoire Feu

Clotilde ETIEMVRE



LABORATOIRE
ESSAIS ET
MESURES

Responsable Technique du Laboratoire
Feu
du Pôle Ameublement


Clémence RAWAS

Siège social
10 rue Galilée
77420 Champs-sur-Marne
Tél + 33 (0)1 72 84 97 84
www.fcba.fr
Siret 775 680 903 00132
APE 7219 Z
Code TVA CEE : FR 14 775 680 903Only the french version remains valide
Institut technologique FCBA : Forêt, Cellulose, Bois - construction, Ameublement