



Approval of the Trademark Trevira CS®

Kinnasand GmbH
Danziger Straße 6
26655 Westerstede
Germany

Application No.:	210344.1
Date of issue:	09.06.2021
Valid until:	09.06.2026
Article name:	6893 Erin II
End use:	Curtains
Square weight (g/m²):	98
According to customer specification	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

The article 6893 Erin II has been tested under the Trevira trademark application no. 210344 and is granted approval for the trademark Trevira CS® for interior use.
The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.
The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.
The article meets the requirements for class 1 according to EN 13773.
This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.
This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH
(This document is valid without signature.)