

# PROCES-VERBAL DE CLASSEMENT DE REACTION AU FEU D'UN MATERIAU



Selon l'article 5 de l'arrêté du 21 Novembre 2002  
Laboratoire agréé par le Ministère de l'Intérieur

## N° CM-26-P-049

Valable 5 ans à compter du 31/03/2026

**Matériau présenté par :**

**Kvadrat A/S**

Lundbergsvej 10

8400 EBELTOFT

**Nature des essais :**

Essai au brûleur électrique  
Essai de persistance de flamme  
Essai de gouttes

**Rapport d'essais :**

FE 26-0094-0496 du 31/03/2026

**Marque commerciale :** HIGHLIGHT 0001

**Description sommaire:** *Le détail de la description du produit est indiqué dans le(s) rapport(s) d'essai en appui cité(s) ci-dessus.*

- Type de support Tissé
- Composition 100% polyester FR
- Masse surfacique 435 g/m<sup>2</sup>
- Epaisseur 0,75mm (donnée laboratoire FCBA)
- Coloris Blanc 0001
- Usage Revêtement de murs tendus, voilages, rideaux,...

## Classement M1

*Ce classement est valable pour toute application pour laquelle le produit n'est pas soumis au marquage CE.*

**Durabilité du classement** Non limitée a priori

**Conditions d'entretien :** selon préconisation du client

**Domaine d'application:** Valable pour toute application pour laquelle le produit n'est pas soumis au marquage CE.

Non valable pour toute application couverte par l'article AM 18 (Arrêté du 6 mars 2006) concernant les sièges rembourrés

*Ce procès verbal atteste uniquement des caractéristiques de l'échantillon soumis aux essais et ne préjuge pas des caractéristiques de produits similaires. Il ne constitue pas une certification de produits au sens de l'article L. 433-3 du code de la consommation et de la loi du 3 juin 1994. Ces conclusions ne portent que sur les performances de réaction au feu de l'élément objet du présent procès-verbal de classement. Elles ne préjugent, en aucun cas, des autres performances liées à son incorporation à un ouvrage.*

Siège social  
10, rue Galilée  
S 81050 Champs-sur-Marne  
77447 Marne-La-Vallée Cedex 2  
Tél +33 (0)1 72 84 97 84

Champs-sur-Marne, le 03/04/2026

Technicien d'essais du Laboratoire Feu

Responsable Technique du Laboratoire Feu  
du Pôle AME

Bordeaux  
Allée de Boutaut – BP 227  
33028 Bordeaux Cedex  
Tél +33 (0)5 56 43 63 00

Isaac FOFANA

Clémence VOISIN

Siret 775 680 903 00132  
APE 7219Z  
Code TVA CEE FR 14 775 680 903

Institut technologique FCBA : Forêt,  
Cellule Bois construction

Ce document comprend 1 page pour le procès-verbal de classement et 1 annexe de 4 pages.

Seules sont autorisées les reproductions intégrales et par photocopies du présent procès-verbal de classement ou de l'ensemble du procès-verbal de classement et rapport(s) d'essais annexé(s)

# Official report of classification of fire performance of a material



Enisaged in article 5 decree of november 21, 2002 . Only french version prevails .

## N° CM-26-P-049

Valid 5 years as from 31/03/2026

### Material presents by :

**Kvadrat A/S**

Lundbergsvej 10

8400 EBELTOFT

### Nature of the test

Electrical burner test  
Flame persistence flame  
Dripping test

### Test report N' :

FE 26-0094-0496 off the 31/03/2026

### Trade mark :

**HIGHLIGHT 0001**

**Summary description:** *Details of the product description are provided in the supporting test report(s) cited above.*

- Kind of textile Tissé
- Composition 100% polyester FR
- Mass per unit area 435 g/m<sup>2</sup>
- Tickness 0,75mm (donnée laboratoire FCBA)
- Color Blanc 0001
- Usual term: Walls hung covering, sheers, curtains,...

## Classement M1

*This classification is valid for any application for which the product is not subject to CE marking.*

**Durability of the classification :** Not limited

**Cleaning conditions :** Recommendation of Customer

**Scope:** This classification is valid for any application for which the product is not subject to CE marking

Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat

*This official report attest only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certificate of products within the meaning of the L.433-3 article of the code of the consumption and the law of June 3rd, 1994. These conclusions relate only to the resistance/reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation into a work.*

Siège social  
10, rue Galilée  
S 81050 Champs-sur-Marne  
77447 Marne-La-Vallée Cedex 2  
Tél +33 (0)1 72 84 97 84

Champs-sur-Marne, 03/04/2026

Technicien d'essais du Laboratoire Feu

Responsable Technique du Laboratoire Feu  
du Pôle AME

Bordeaux  
Allée de Boutaut – BP 227  
33028 Bordeaux Cedex  
Tél +33 (0)5 56 43 63 00

Isaac FOFANA

Clémence VOISIN

Siret 775 680 903 00132  
APE 7219Z  
Code TVA CEE FR 14 775 680 903

Institut technologique FCBA : Forêt, Cellulose, Bois - construction, Ameublement | [www.fcba.fr](http://www.fcba.fr)

This document includes 1 page for the classification report and et 1 annexe de 4 pages.

Only full reproductions by photocopies of this classification report or of the entire classification report are authorized.  
and attached test report(s)