

For the Account of Kvadrat A/S
Lundbergsvej 10
8400 Ebeltoft Denmark

Client's Identification HALOS

CERTIFICATE OF TESTING

TEST PERFORMED NFPA 701 Standard Methods of Fire Test for Flame Propagation of Textiles and Films 2023 – Test #1

TEST RESULTS

Specimen	Mass Initial (g)	Mass Final (g)	Mass Loss (%)	Drip Burn (s)	Afterflame (s)
1	14.2	9.1	36	0.0	0.0
2	14.2	9.1	36	0.0	0.0
3	13.9	8.4	40	0.0	0.0
4	13.9	8.4	40	0.0	0.0
5	14.2	8.9	37	0.0	0.0
6	14.2	9.2	35	0.0	0.0
7	14.1	8.8	38	0.0	0.0
8	14.0	8.4	40	0.0	0.0
9	13.9	8.8	37	0.0	0.0
10	13.9	8.7	37	0.0	0.0
Average	14.1	8.8	38	0.0	0.0

NOTES

Approximate weight (oz./sq. yd) 6.9 **Standard Deviation** 1.8 **Mean + 3 SD** 43.4

Product Configuration ☒ Single Layer ☐ Multi Layer
Material Tested Initially
Test Environment 70 ±4°F, 50 ±5% Relative Humidity
Conditioning ☒ Oven at 220°F (30 minutes) ☐ 70 ±4°F & 65 ±5%RH for 24 hours
Sampling As Received
Intended End-use Drapery

ACCEPTANCE CRITERIA

Afterflame is required to be recorded; however, it is not factored into the Acceptance Criteria

1. Drip burn (Flaming Drip) shall not exceed an average of 2 seconds per specimen for the sample of 10 specimens
2. Mass Loss shall not exceed 40% for the average of 10 specimens
3. Individual specimen mass loss shall not exceeds mean + 3 SD

CONCLUSION

Based on the above Results and Acceptance Criteria, the item tested:

- ☒ Complies
☐ Does Not Comply
☐ Testing of 10 additional specimens is required

CERTIFICATION I certify that the above results were obtained after testing specimen in accordance with the procedures and equipment specified by the standard stated above.



Authorized Signature

Date Order Completed: 05/06/2026