

Simulation of Sound Absorption Coefficient as per ISO 354

Computational model* of absorption measurement in reverberation rooms

Client Kvadrat
Test Specimen Curtains
 Type: Flat

Arrangement: Flat hanging

1 layer of textile, flat arrangement
 Distance to the wall: 100 mm

Front textile: Plecto from Febrik / Kvadrat

Back side textile: -

Simulated module build-up (from top to bottom):

1.44 mm	Front textile
100 mm	Air gap
	Concrete surface

Simulation set up:


Flat arrangement, 100mm to the wall

No surrounding, enclosing frame

Simulation reproduces the standard ISO 354/11654
 measurement - random incidence environment

Date of simulation: 03-03-20

Frequency [Hz]	α_s 1/3 octave	α_p octave
100	0.01	
125	0.02	0.00
160	0.03	
200	0.05	
250	0.07	0.10
315	0.12	
400	0.17	
500	0.23	0.25
630	0.29	
800	0.36	
1000	0.41	0.40
1260	0.39	
1600	0.30	
2000	0.24	0.30
2500	0.34	
3160	0.39	
4000	0.37	0.40
5000	0.41	



*Method reproduces conditions, dimensions, build-up in a way results are comparable with measurements in reverberation chamber

α_s Sound absorption coefficient to ISO 354

α_p Practical sound absorption coefficient to ISO 11654

Rating according to ISO 11654:

NRC: 0.25

SAA: 0.25

Weighted Sound Absorption Coefficient $\alpha_w = 0.3$

Sound absorption class: D

kvadrat soft cells

Test conducted by Kvadrat SoftCells
 Poznańska 3, 62-023 Gądki