



## Approval of the Trademark Trevira CS®

Kvadrat A/S  
Danziger Str. 6  
26655 Westerstede  
Germany

|  |                    |
|--|--------------------|
| <b>Application No.:</b>                  | 200772.1           |
| <b>Date of issue:</b>                    | 07.12.2020         |
| <b>Valid until:</b>                      | 26.11.2025         |
| <b>Article name:</b>                     | 6774 Mori          |
| <b>End use:</b>                          | Drapes<br>Curtains |
| <b>Square weight (g/m<sup>2</sup>):</b>  | 102                |
| According to customer specification      |                    |
| <b>Composition of the raw materials:</b> | Polyester 100%     |
| <b>Composition of the fabric:</b>        | Trevira CS 100%    |

The tested article 6774 Mori with application no. 200772.1 is granted approval for the trademark Trevira CS® for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

The article meets the requirements for class 1 according to EN 13773.

Trevira GmbH  
(This document is valid without signature.)