

Received: 12/06/2006	Completed: 12/11/2006	Letter: J	rb	P.O.#:	Test Report #:	2-65369-0-
Client's Identification	Pattern: Molly by Kvadrat					
Tested For:	kvadrat DK - 8400 Ebeltoft		Key Test: NFPA 260 Cover Fabric (BLDG)			85
				Tel: 1-(631)-851-3215	Ext:	
				Fax: 1-(631)-232-2659		

PC: 4H /jd

TEST PERFORMED: NFPA 260 Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture; Cover Fabric Test

RESULTS:	TEST		RETEST (If Required)		
	Specimen #	Ignition (yes/no/SE)	Char Length On Vertical Panel (mm)	Ignition (yes/no/SE)	Char Length On Vertical Panel (mm)
	1	No	12		
	2	No	16		
	3	No	10		

ABBREVIATION WHICH MAY BE USED:

SE: Indicates that the cigarette self extinguished prior to burning its entire length. When this occurs, a "retest" of that specimen is performed.

REMARKS: None.

CLASSIFICATION SYSTEM:

Class I - For each specimen: No obvious ignition; maximum char length 45 mm (1.75").
(Indicates propensity to resist cigarette ignition in conjunction with standard foam filling material.)

Class II - For any specimen: Obvious ignition; or char length exceeding 45 mm (1.75").
(Indicates inability to resist cigarette ignition in conjunction with standard foam filling material.)

CONCLUSION: Based on the above Results and Classification System, the item tested is assigned a:

Class I rating; Class II rating



Received: 12/06/2006	Completed: 12/11/2006	Letter: J	rb	P.O.#:	Test Report #:	2-65369-0-
Client's Identification	Pattern: Molly by Kvadrat					
Tested For:	kvadrat DK - 8400 Ebeltoft		Key Test: NFPA 260 Cover Fabric (BLDG)			85
			Tel: 1-(631)-851-3215		Ext:	
			Fax: 1-(631)-232-2659			

CODE INFORMATION: In accordance with --

- (1) The 2006 Edition of the NFPA Life Safety Code 101 paragraph 10.3.2.1(1);
- (2) The 2006 Edition of the International Fire Code, paragraph 805.1.1.1, 805.2.1.1 and 805.3.1.1

Upholstered furniture components shall be Class I when tested in accordance with NFPA 260, when used in:

- Detention or correctional occupancy
- Health care occupancy
- Residential board & care occupancy

In certain situations an exception is made if the rooms or areas are sprinklered.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 260.

Heather E. Robertson

AUTHORIZED SIGNATURE
THE GOVMARK ORGANIZATION, INC. /rb

MS. HEATHER ROBERTSON

(Page 2 of 2)