



96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
e-mail: info@govmark.com

Received:04/04/2012	Completed:04/05/2012	Letter: X5	rb	P.O.#:	Test Report #:	2-91730-5-
Client's Identification	Style: Divina MD by Kvadrat.					
Tested For:	kvadrat DK - 8400 Ebeltoft		Key Test: NFPA 260 Cover Fabric (BLDG)		135	
			Tel: 1-(631)-282-6318		Ext:	
			Fax: 1-(631)-282-6410			

CONCLUSION: Based on the above Results and Classification System, the item tested is assigned a:

Class I rating; Class II rating

REMARKS: None.

CODE INFORMATION: In accordance with --

- (1) The 2009 Edition of the NFPA Life Safety Code 101, paragraph 10.3.2.1(1); and
- (2) The 2009 Edition of the International Fire Code, paragraph 805.1.1.1, 805.2.1.1, 805.3.1.1, and 805.4.1.1

Upholstered furniture components shall be Class I when tested in accordance with NFPA 260, when used in:

- Detention or correctional occupancy
- Health care occupancy
- Residential board & care occupancy
- College and university dormitories

COMMENTARY: The cigarette ignition source used in this test conforms to the physical parameters set forth in the test standard. The actual propensity of the cigarette (that is currently manufactured) to cause ignition of materials under test might be different than the cigarette that was manufactured at the inception of the test standard.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 260.

AUTHORIZED SIGNATURE
THE GOVMARK ORGANIZATION, INC. / ec

MS. HEATHER ROBERTSON

APR 18 2012



Received:06/14/2004 Completed:06/15/2004 Letter: D rb P.O.#: Test Report #: 2-51509-0-

Client's Identification Divina By Kvadrat

Tested For: Anna DeMatteo **kvadrat** Key Test: NFPA 260 Cover Fabric 80
DK - 8400 Ebeltoft Tel: 1-(631)-851-3342 Ext:
Fax: 1-(631)-342-0264

PC: 4H

TEST PERFORMED: NFPA 260 Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture; Cover Fabric Test

RESULTS:

Specimen #	Ignition (yes/no/SE)	Char Length		RETEST (If Required)	
		On Vertical Panel (mm)	On Vertical Panel (mm)	Ignition (yes/no/SE)	Char Length (mm)
1	No	12			
2	No	18			
3	No	13			

SE: Indicates that the cigarette self extinguished prior to burning its entire length. When this occurs, a "retest" of that specimen is performed.

REMARKS: None.

CLASSIFICATION SYSTEM:

Class I - For each specimen: No obvious ignition; maximum char length 45 mm (1.75").
(Indicates propensity to resist cigarette ignition in conjunction with standard foam filling material.)

Class II - For any specimen: Obvious ignition; or char length exceeding 45 mm (1.75").
(Indicates inability to resist cigarette ignition in conjunction with standard foam filling material.)

CONCLUSION: Based on the above Results and Classification System, the item tested is assigned a:

Class I rating Class II rating

CODE INFORMATION: In accordance with the 2003 Edition of the NFPA Life Safety Code 101 paragraph 10.3.2(1), upholstered furniture components shall be Class I when tested in accordance with NFPA 260, when used in health care, detention, and correctional occupancies. In certain situations, an exception is made if the rooms or areas are sprinklered.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 260.

Heather E. Robertson

AUTHORIZED SIGNATURE
THE GOVMARK ORGANIZATION, INC. /jd

MS. HEATHER E. ROBERTSON

(Page 1 of 1)