

Received:06/14/2004	Completed:06/15/2004	Letter: D	rb	P.O.#:	Test Report #:	2-51509-0-
Client's Identification	Divina By Kvadrat					
Tested For: Anna DeMatteo	kvadrat DK - 8400 Ebeltoft		Key Test: NFPA 260 Cover Fabric			80
			Tel: 1-(631)-851-3342		Ext:	
			Fax: 1-(631)-342-0264			

PC: 4H

TEST PERFORMED: NFPA 260 Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture; Cover Fabric Test

RESULTS:

Specimen #	Ignition (yes/no/SE)	Char Length		RETEST (If Required)	
		On Vertical Panel (mm)	On Vertical Panel (mm)	Ignition (yes/no/SE)	Char Length (mm)
1	No	12			
2	No	18			
3	No	13			

SE: Indicates that the cigarette self extinguished prior to burning its entire length. When this occurs, a "retest" of that specimen is performed.

REMARKS: None.

CLASSIFICATION SYSTEM:

Class I - For each specimen: No obvious ignition; maximum char length 45 mm (1.75").
(Indicates propensity to resist cigarette ignition in conjunction with standard foam filling material.)

Class II - For any specimen: Obvious ignition; or char length exceeding 45 mm (1.75").
(Indicates inability to resist cigarette ignition in conjunction with standard foam filling material.)

CONCLUSION: Based on the above Results and Classification System, the item tested is assigned a:

Class I rating Class II rating

CODE INFORMATION: In accordance with the 2003 Edition of the NFPA Life Safety Code 101 paragraph 10.3.2(1), upholstered furniture components shall be Class I when tested in accordance with NFPA 260, when used in health care, detention, and correctional occupancies. In certain situations, an exception is made if the rooms or areas are sprinklered.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 260.

Heather E. Robertson

AUTHORIZED SIGNATURE
THE GOVMARK ORGANIZATION, INC. /jd

MS. HEATHER E. ROBERTSON

(Page 1 of 1)