

Laboratory approved by the Ministry for the Interior
JO of February 10, 2007OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE
Of A MATERIAL ENVISAGED IN ARTICLE 5
DECREE OF November 21, 2002

N° CM - 19 - P - 008

Page 1

et 1 annexe de 4 pages.

Valid 5 years as from lundi 21 janvier 2019

Material presents by : **KINNASAND GMBH**Danziger strasse 6
26655 WESTERSTEDETrade mark: **LOOX 6860**

Summary description

Kind of textile **dobby, plain wave**Composition **100% polyester FR**Mass per unit area **244 g/m²**Tickness **0,7 mm (donnée laboratoire FCBA)**Color **tous coloris**Nature of the test : **Electrical burner test**
Flame persistence
Dripping testClassification : **M1**

Observations : /

Durability of the classification (Article 5 de l'annexe 2) **Not limited**Usual term **Walls hung covering, sheers, curtains,...**Cleaning conditions **Recommendation of Customer**

Taking into account the criteria resulting from the tests annexed described in the test report N°FE 18-0411-2019

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"

Champs-sur-Marne, le jeudi 24 janvier 2019

Technicienne d'essais
du Laboratoire Feu

Clotilde ETIEMVRE

Responsable Technique du Laboratoire
Feu

du Pôle Ameublement


Clémence RAWAS

Only the french version remains valide

Institut technologique FCBA : Forêt Cellulose, Bois Construction, Ameublement