

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

Group Number Assessment

(In accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing.

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

Test Sponsor: Kvadrat A/S

Lundbergsvej 10 Ebeltoft 8400 Denmark

Denmark

Sponsor Product Clients Ref : "Husk 0124 Smoke"

Knitted wadded fabric
Colour: Taupe
End Use: Wall Covering

Lild 03C. Wall Covering

Nominal Composition : $\,$ 66% Polyester filling, 15% New Wool, 9% Nylon, 9% Polyester , 1% $\,$

Elastane

Nominal Mass per Unit Area/Density: Approx: 600g/m2

Product Group Number Classification: 3

Average Specific Extinction Area: 143.3 m²/kg

0."

Chris Campbell
Client Relations Manager

42551

20-000865

30/03/2020

30/03/2020

Test Number :

Issue Date

Print Date

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. It's transmission is not intended to place the contents into the public domain.