

A Division of Australian Wool Testing Authority Limited

A.B.N. 43 006 014 106 Laboratory: 1st Floor, 191 Racecourse Rd, Flemington, Victoria 3031 P.O. Box 240 Nth Melbourne 3051 Tel: (03) 9371 2400 Fax: (03) 9371 2499 Website: www.awtaproducttesting.com.au Email: producttesting@awta.com.au

Group Number Assessment

(in accordance with AS 5637.1-2015)

Number: 1709001 Issue Date: 22/9/2017

This is to confirm that the product as described below has been tested by AWTA Product Testing.

Testing was performed in accordance with AS/NZS 3837 - 1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

AWTA Product Testing report number: 7-585575-CO

Date of Test: 21/06/2012

Test Sponsor

Kvadrat A/S Lundbergsvej 10 Ebeltoft 8400 Denmark

Sponsor Product Reference: "Sunniva"

Sponsor Product Description: Woven fabric tested loose laid on cement sheet

Colour: Green Nominal Composition: 62% wool 25% viscose 8% linen 5% polyamide

Product Group Number Classification: Group 2 Average Specific Extinction Area: 20.1 m²/kg

Sean Bassett Divisional Manager

It should be borne in mind that the opinions expressed in this letter are based on a limited number of observations made on a single sample and may be subject to alteration if more detailed testing was to be carried out. We recommend that you have further testing conducted if the information above is critical to your decisions on this product.

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. Its transmission is not intended to place the contents into the public domain.