



Approval of the Trademark Trevira CS®

Kvadrat A/S
Danziger Str. 6
26655 Westerstede
Germany

Application No.:	190919.1
Date of issue:	07.01.2020
Valid until:	16.09.2024
Article name:	6992 Swell
End use:	Curtains
Square weight (g/m²):	62
<i>According to customer specification</i>	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%
Yarn:	Warp, 22 f 1 x 1 dtex Trevira® Type 695V, Yarn supplier Torcitura Padana Weft, 22 f 1 x 1 dtex Trevira® Type 695V, Yarn supplier Torcitura Padana Weft, 350 f 128 x 1 dtex Trevira® Type 691, Yarn supplier Trevira

The tested article 6992 Swell with application no. 190919.1 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

This article has been tested according to NF P 92-504 (Propagation of flames) and has reached class M2.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

The article meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Trevira GmbH
(This document is valid without signature.)