



Date of Issue: 10/22/2020 Report Number: 20-003342

Revision Number:1

Date Order Received: 10/12/2020

For the Account of: Kvadrat A/S

Lundbergsvej 10 DK-8400 Ebeltoft

Client's	Identification:	Zulu 104

CERTIFICATE OF TESTING

TEST PERFORMED: NFPA 701 Standard Methods of Fire Test for Flame Propagation of Textiles and Films 2019 – Test #1

TEST RESULTS

Specimen	Mass Initial (g)	Mass Final (g)	Mass Loss (%)	Drip Burn (s)	Afterflame (s)
1	5.1	3.2	37	0.0	0.0
2	5.1	3.3	35	0.0	0.0
3	5.1	3.0	41	0.0	0.0
4	5.1	3.4	33	0.0	0.0
5	5.1	3.5	31	0.0	0.0
6	5.1	3.1	39	0.0	0.0
7	5.2	3.5	33	0.0	0.0
8	5.2	3.2	38	0.0	0.0
9	5.2	3.2	38	0.0	0.0
10	5.1	3.2	37	0.0	0.0
Average	5.1	3.3	36	0.0	0.0

Approximate weight (oz./sq. yd): 2.5	Standard Deviation: 3.1	Average + 3 SD : 45.3
Product Configuration: Conditioning: Market Single Conditioning: Market Single Conditioning: Market Single	at 220°F for minimum 30 minutes	☐ 70 ±2°F & 65 ±2%RH for minimum 24 hours
seconds per specimen for the sam 2. Where the average weight loss of the same state	ecimens that fall to the floor of the test cha ple of 10 specimens, the material shall be the 10 specimens in a sample is greater that as a failure if it exceeds mean + 3 SD	mber continue to burn for more than an average of 2 recorded as failing. (Flaming Drip) an 40 percent, the material shall be recorded as failing. ther of the conditions indicated above, the material shall
specified by the standard stated above.	Its were obtained after testing specimen in	accordance with the procedures and equipment
Suthorized Signature		Date Order Completed: 10/20/2020

553 76th Street, Byron Center, MI 49315

P: 616-559-6123 E: testlab@applied-lab.com

Page 1 of 1