

Müller-BBM GmbH
Robert-Koch-Str. 11
82152 Planegg bei München

Telephone +49(89)85602 0
Telefax +49(89)85602 111

www.MuellerBBM.de

M.Eng. Philipp Meistring
Telephone +49(89)85602 228
Philipp.Meistring@MuellerBBM.de

2012-11-09
M100827/07 MSG/JRE

Upholstery fabric Canvas Manufacturer Kvadrat A/S

**Determination of the
airflow resistance according to EN 29053**

Test Report No. M100827/07

Client:	Kvadrat A/S Lundbergsvej 10 DK – 8400 Ebeltøft
Consultant:	M.Eng. Philipp Meistring
Date of report:	2012-11-09
Date of delivery:	2012-11-06
Date of test:	2012-11-08
Total number of pages:	In total 6 pages: 4 pages text, 1 page Appendix A and 1 page Appendix B.

Certified quality management system according to ISO 9001
Accredited testing laboratory according to ISO/IEC 17025

Müller-BBM GmbH
HRB Munich 86143
VAT Reg. No. DE812167190

Managing directors: Horst Christian Gass,
Dr. Carl-Christian Hantschk, Stefan Schierer,
Dr. Edwin Schorer, Norbert Suritsch

Table of contents

1	Task	3
2	Basics	3
3	Test object	3
4	Execution of measurements	3
5	Measurement results	4
6	Remarks	4

Appendix A: Measurement results and evaluation

Appendix B: List of test equipment

1 Task

On behalf of Kvadrat A/S, DK – 8400 Ebeltoft, the airflow resistance of the upholstery fabric type Canvas has to be measured according to EN 29053 [1].

2 Basics

This test report is based on the following documents:

- [1] EN 29053 “Acoustics – Materials for acoustical applications – Determination of airflow resistance”. 1993

3 Test object

The tested material is described by the manufacturer as follows:

- Upholstery fabric type Canvas
- manufacturer Kvadrat A/S
- material: 90 % new wool, 10 % nylon

The test laboratory has determined the following parameters:

- area specific mass $m'' = 323 \text{ g/m}^2$
- thickness $t = 0.72 \text{ mm}$

4 Execution of measurements

The airflow resistance was determined according to EN 29053 [1].

The measurements for the determination of the airflow resistance were carried out at different air velocities. The continuous airflow method was applied. The specimen holder has a diameter of 100 mm. The test specimen was fitted flat over the specimen holder, without stretching the material, sealed at the edges and fixed.

According to the standard the specific airflow resistance R_s is indicated as measurement result which was determined by extrapolation (linear regression) at an airflow velocity of $u = 0.0005 \text{ m/s}$.

The test equipment listed in Appendix B was used for the measurements.

5 Measurement results

For the tested upholstery fabric type Canvas, a specific airflow resistance of $R_s = 559 \text{ Pa} \cdot \text{s/m}$ was determined.

For further information regarding the measurements, see Appendix A.

6 Remarks

The determined test results only refer to the prevailing conditions on the day of measurements.

This test report may only be published and copied as a whole including all of its appendixes. The publishing of extracts requires the prior written consent of Müller-BBM GmbH.



M. Eng. Philipp Meistring



Durch die DAkkS Deutsche Akkreditierungsstelle GmbH
nach DIN EN ISO/IEC 17025 akkreditiertes Prüflaboratorium.
Die Akkreditierung gilt für die in der Urkunde aufgeführten Prüfverfahren.


EN 29053
Determination of airflow resistance

Client: Kvadrat A S
8400 Ebeltoft Denmark
Order Number: M100827
Müller-BBM Probe Number: 8283
Test object: - upholstery fabric type Canvas
- material: 90% new wool, 10% nylon

Diameter: 100 mm
Thickness: 0.72 mm
Area-specific mass: 323 g/m²

Barometric pressure:
 $B = 95,6 \text{ kPa}$
Temperature:
 $\theta = 22,8 \text{ °C}$
Relative humidity:
 $r. h. = 20,4 \%$

$u/$ (mm/s)	$R_s/$ (Pa s/m)
3.46	557
4.94	551
6.41	551
7.89	551
9.38	551
10.85	543
12.33	546



Airflow resistance $R_s = 559 \text{ Pa s/m}$

MÜLLER-BBM

Laboratory: Planegg
Responsible: prgls / msg
Date: 2012/11/08

List of test equipment

For the measurements and evaluations, the following test equipment was applied:

Name	Manufacturer	Type	Serial-No.
air flow resistance measurement system	Müller-BBM	M89319-00	315003
Software for data logging and evaluation	Müller-BBM	m ars	v1.0.0.2
Digital measuring slide	Mitutoyo	CD-15PPR	07019377
Electronic balance	Kern	440-49N	WC0633572